

SIEMENS RMS705B QUICK HELP SHEET by HEVAC.

PROCEDURE TO ADJUST SIEMENS RMS705B TIME SWITCH ON/OFF TIMES.

- 1.) PRESS "OK" KNOB > MAIN MENU IS DISPLAYED
- 2.) ROTATE "OK" KNOB UNTIL "...**TIME SWITCH**" IS HIGHLIGHTED
- 3.) PRESS "OK" KNOB
- 4.) ROTATE "OK" KNOB UNTIL MONDAY'S TIMES ARE DISPLAYED
- 5.) PRESS "OK" KNOB > THE "FROM" TIME WILL BE DISPLAYED --THIS IS THE CURRENT START TIME
- 6.) PRESS "OK" KNOB > THE CURRENT START TIME FOR EDITING IS DISPLAYED IN A SMALL BOX
- 7.) ROTATE THE "OK" KNOB UNTIL THE REQUIRED START TIME IS DISPLAYED
- 8.) PRESS "OK" **TWICE** > DISPLAY RETURNS TO STATE AFTER STEP 4.) WAS COMPLETED
- 9.) ROTATE "OK" KNOB SO THAT THE EXISTING (FROM) FINISH (OFF) TIME IS DISPLAYED i.e. 22:00
- 10.) REPEAT STEPS 6 TILL 8 TO EDIT FINISH TIME FOR MONDAY.
- 11.) PRESS "ESC" TO RETURN TO STATUS SCREEN POST STEP 4.)
- 12.) ROTATE "OK" KNOB TO THE NEXT DAY IS DISPLAYED
- 13.) REPEAT STEPS 5.) TO 11.) UNTIL ALL DAYS ARE PROGRAMMED.
- 14.) TO FINISH, PRESS "ESC" REPEATEDLY UNTIL MAIN RUNNING SCREEN IS DISPLAYED

PROCEDURE TO SET HOLIDAY OFF OVERRIDE DATES

- 1.) PRESS "OK" KNOB > MAIN MENU IS DISPLAYED
- 2.) ROTATE "OK" KNOB TILL MENU TITLED "**HOLIDAYS/SPECIAL DAYS**" IS DISPLAYED.
- 3.) PRESS "OK" KNOB > "ENTRY 1" HOLIDAY DATES IS DISPLAYED
- 4.) ROTATE "OK" KNOB TILL CORRECT HOLIDAY START DATE IS DISPLAYED
- 5.) PRESS "OK" KNOB, ALTER TRIGGER TIME & REPEAT "OK" TILL HOLIDAY END DATE IS DISPLAYED
- 6.) ROTATE "OK" KNOB TILL CORRECT HOLIDAY END DATE (INCLUSIVE) IS DISPLAYED
- 7.) PRESS "OK" KNOB, ALTER TRIGGER TIME IN NECESSARY.
- 8) PRESS "ESC" BUTTON AND ROTATE DOWN TO NEXT ENTRY FOR EDITING
- 9.) REPEAT ABOVE PROCEDURE FOR OTHER HOLIDAYS (ENTRY'S 1-18)

PROCEDURE TO CORRECT TIME & DATE

- 1.) PRESS "OK" KNOB > MAIN MENU IS DISPLAYED
- 2.) ROTATE "OK" KNOB TILL MENU TITLED "**TIME & DATE**" IS DISPLAYED.
- 3.) PRESS "OK" AND ALTER TIME & DATE AS NECESSARY.
- 4.) ALSO **CHECK DAY LIGHT SAVING TRIGGER DATES** ARE CORRECT, ADJUST IF REQUIRED.
- 5.) PRESS ESCAPE TILL MAIN OPERATING DISPLAY IS RETURNED.

PROCEDURE TO ADJUST SIEMENS RMS705B TEMPERATURE SETPOINTS.

- 1.) PRESS "OK" KNOB > MAIN MENU IS DISPLAYED
- 2.) ROTATE "OK" KNOB TO SCROLL DOWN THE MENU TREE UNTIL "(*ZONE TITLE or TEMP*)
CONTROLLER" IS HIGHLIGHTED (zone name varies with project)
- 3.) PRESS "OK" KNOB
- 4.) ROTATE "OK" KNOB UNTIL "**SET POINT LOW**" (*WHICH IS THE HEATING SET POINT*) IS DISPLAYED
- 5.) PRESS "OK" KNOB > ROTATE KNOB UNTIL THE DESIRED (HEATING) SET POINT LOW VALUE IS DISPLAYED
- 6.) PRESS "OK" KNOB, THEN ROTATE KNOB UNTIL "**SET POINT HIGH**" (COOLING SET POINT) IS DISPLAYED
- 7.) PRESS "OK" KNOB > ROTATE KNOB UNTIL THE DESIRED (COOLING) SET POINT HIGH VALUE IS DISPLAYED
- 8.) PRESS "OK" KNOB.
- 9.) REPEAT PROCEDURE FOR OTHER 2 POSSIBLE ZONE TEMP. CONTROLLERS TO CHANGE THOSE SETPOINTS.
- 10.) PRESS "ESC" REPEATEDLY TO EXIT TO NORMAL RUNNING DISPLAY.

NOTE:

TO SEE CURRENT STATUS OF ALL INPUTS, IN THE MENU SYSTEM UNDER A MENU CALLED "**INPUTS**" PRESS OK KNOB & THEN ROTATE TO SEE ALL INPUT VALUES.